


AGNI-System №AE-226

Step-by-step installation instructions:

1. Apply AGNI-Black in the annular space to the depth of the AGNI-Board, 100mm (nominal) deep and finished flush with both faces of the AGNI-Board.
2. Make a 20x20mm fillet/cone of AGNI-Black applied on the unexposed face.



Technical Information

System ID	AE-226
Substrate	2 x layers of AGNI-Board in min. 120mm concrete floor/ceiling
Service range	13 x TPS cables
Annular gap	10.8-17.2mm
AGNI-Products	AGNI-Black
Protection installation	Asymmetrical

Compliance Information

Standards	AS1530.4-2014, AS4072.1-2005
FRR/FRL	-/120/120
Reference	PF25041




8 Clare St Bayswater
VIC 3153, AUSTRALIA
+61 (03) 7045 4242
info@agnitek.com.au
www.agnitek.com.au

Disclaimer

Agnitek reserves the right to modify product specifications without prior notice due to its ongoing research, development & certification programme. The information in this document is provided in good faith and is intended for guidance purposes only. Any accompanying drawings are solely for illustrative purposes. Since Agnitek cannot oversee installation methods or ensure site conditions, no warranties, expressed or implied, are intended regarding the products' actual performance. We do not accept liability for any loss, damage, or injury from using this information. Please take a look at the test reports displayed on a relevant AGNI-System webpage for all compliance specifics.

Date	10.06.2025
------	------------



Technical Information

System ID	AE-226
Substrate	2 x layers of AGNI-Board in min. 120mm concrete floor/ceiling
Service range	13 x TPS cables
Annular gap	10.8-17.2mm
AGNI-Products	AGNI-Black
Protection installation	Asymmetrical

Compliance Information

Standards	AS1530.4-2014, AS4072.1-2005
FRR/FRL	-/120/120
Reference	PF25041



8 Clare St Bayswater
 VIC 3153, AUSTRALIA
 +61 (03) 7045 4242
 info@agnitek.com.au
 www.agnitek.com.au

Disclaimer
 Agnitek reserves the right to modify product specifications without prior notice due to its ongoing research, development & certification programme. The information in this document is provided in good faith and is intended for guidance purposes only. Any accompanying drawings are solely for illustrative purposes. Since Agnitek cannot oversee installation methods or ensure site conditions, no warranties, expressed or implied, are intended regarding the products' actual performance. We do not accept liability for any loss, damage, or injury from using this information. Please take a look at the test reports displayed on a relevant AGNI-System webpage for all compliance specifics.

Date	10.06.2025
------	------------